

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2022/ 868

Dated:- 10/08/2022

FIRE SAFETY CERTIFICATE

Certified that the **Amity International School** located at **Mayur Vihar Phase-1, Delhi-91** comprised of **Basement + Ground + 04 Upper floors**, owned/occupied by Amity International School has already been issued Fire Safety Certificate vide letter No. **F6/DFS/MS/School/ 2019/438 dated 26/02/2019**. The premises was re-inspected by the officers concerned of this department on **30/07/2022** in the presence of the Mr. Sunil Pandit (Admin Officer) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with NBC Part-IV and premises is fit for occupancy of class **“Educational Building” (Group B)** with effect from ~~10/8/22~~ renewed for a period of three years, subject to conditions printed below.

Issued on10.8.22..... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Director of Education,
Government of N.C.T. Delhi,
Old Sectt. Delhi – 110054.
2. The Principal,
Amity International School,
Mayur Vihar Phase-1, Delhi-91.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.