



No. F6/DFS/MS/School/NDZ/2025/923

Dated: 25/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Amity International School located at Mayur Vihar Phase - 1, Delhi - 110091 comprised of Basement + Ground + 04 Upper floors, owned/occupied by Amity International School, was granted FSC by this department vide letter No. F6/DFS/MS/School/NDZ/2022/868 dated 10/08/2022. The premises was re-inspected by the officers concerned of this department on 10/07/2025 in the presence of the Mr. Sunil Pandit (Admin Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "B" 'Educational Building' Basement + Ground + 04 Upper floors with effect from 25/07/2025 for a period of three years, subject to conditions, printed below.

Issued on 25/07/2025 at New Delhi by.

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

**Copy to: -**

1. The Director Education, D - Block, Anand Vihar, Delhi - 110091.
2. The Principal, Amity International School located at Mayur Vihar Phase - 1, Delhi - 110091.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (i) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**